Instructions

Complete cells in grey(inputs)

This will consist of selecting from drop down boxes or in The TCO considers two types of grid scenario which shou **Stable grid float application:** Stable ambient temperatur **Unreliable grid cycling:** Unstable grid, warm ambient ter

Definition of Terms & Parameters

Type of battery	
Technology	
Nominal Capacity (Label Rating) (Ah)	
Service Life @ 20°C in Float Application	
Cost/block	
Battery Capex cost ratio	
Number of blocs per string	
Number of parallel strings	
Installed battery capacity (Ah)	
Installed battery capacity (kWh)	
Total battery cost	
Capex cost / 100Ah	
Capex cost/kWh	
Depth of discharge	
Cycles per day (Unreliable Grid)	

TCO TERM
Currency
Transportation & installation costs
Overhead
Interest rate
Maintenance costs (cost per year)
Energy cost / kWh
Temperature
No. of Sites

140. 01 31163	
Usable capacity (kWh)	
Battery Lifetime energy throughput (kWh) (Unreliable Grid only)	
No. of Battery Investments (Initial + Replacements over TCO term)	

a) Annuity of investment

Investment over TCO Term

Float current (A)
Battery energy consumption / year (kWh)
Battery energy consumption cost / year
b) Maintenance and service costs /year

Total cost of ownership / year (sum a&b)	
Total cost of ownership / year / kWh	
TCO ratio	

Savings per site	
Total Savings	

putting the values relative to the TCO scenario being investigated Id be used depending on the grid conditions of the site re, compensation to float voltage for any temperature fluctuation. No or very little cyclic use. mperature with uncontrolled cyclic use. Medium to High cyclic use with multiple outages per week

Drop down box to select the battery technology range of interest

Dependent on the product range selected this maybe TPPL or Standard AGM such as PbCa or PbCaSn AGM technology

Insert battery capacity of interest which is being used as part of the sizing of the system

Insert either the design life of chosen battery range in stable 20°C controlled conditions or the estimated service life @ estimated optimum life (Typically for Telecom 80% of the Design Life)

Cost per 12V monobloc (in chosen currency)

Ratio calculated relative to the cost per bloc. This is normalised to the cost of the bloc from the first column

Enter number of blocs per string from sizing

Enter number of string per battery from sizing

Calculated relative to the nominal capacity of the battery and sizing (No. of blocs per string & No. of parallel strings) in *I* Calculated relative to the nominal capacity of the battery and sizing (No. of blocs per string & No. of parallel strings) in *I* k

Relative to the number of blocs in the battery and the monobloc cost

Relative to the total battery cost and 100Ah available

Relative to the total battery cost and battery capacity in kWh

Enter the % amount of battery capacity utilised during a typical outage (dependent on battery sizing & site conditions)

Enter typical frequency of power outages

The period over which the TCO calculation is based (typically 10 years for stable grid and 5 years for unreliable grid)

Currency can be selected from pull down menu. Monetary values will need to be entered & adjusted in this currency

Cost to transport and install batteries

Cost of procurement, storage of batteries

Interest rate applied to the battery investment over the service life term of the battery. Can be set to zero to show cash i

Cost to carry out regular maintenance checks on the batteries

The local cost of energy which will impact the ongoing running costs

Typical operating temperature of the batteries

Total number of sites to be considered in the roll out of this TCO scenario

Amount of capacity of the battery utilised relative to the nominal capacity and depth of discharge

For cyclic application in unreliable Grid application. Multiplication of the useable battery capacity and number of cycl typical depth of discharge

Number of battery purchases that will be required over the TCO term. Dependent on TCO term and service life of the ba Sum of the Battery cost + Transport & Installation Cost + Overhead multiplied by the number investments required in t

Investment per year over the TCO term. Dependent on the Battery Investment, Interest rate and TCO term

Float current dependent on the battery technology and battery capacity. TPPL assumes a float current of 20mA/100 Ah 35mA/100 Ah

Energy consumption of the battery during float over the period of a year.

Dependent on the energy consumption of the battery from float charge per year and depending on the local energy cost Total cost of energy and servicing per year

TCO per year = Sum of the Annuity of investment + Maintenance & Service Costs

TCO per year divided by the useable battery capacity

Ratio between each of the different product types. This is normalised to the first battery type being studied

Total savings per site relative to the scenario in the first column. Red, yellow and Green colours indicate good-better-be Total savings dependent on the savings per site and the number of sites

Total Cost of Ownership (TCO) Calculator | Post Action |

EnerSys.

Product range	Technology
DataSafe HX	Std AGM
DataSafe HX+	TPPL
DataSafe XE	TPPL
PowerSafe V	Std AGM
PowerSafe V-FT	TPPL
PowerSafe SBS EON	TPPL
PowerSafe SBS XL	TPPL
Standard AGM	Std AGM

Unreliable range		
PowerSafe SBS EON	56918	0.96
PowerSafe V-FT	35553	0.971
Standard AGM	26664.75	0.971

Selected battery range	PowerSafe SBS XL	PowerSafe SBS EON
Design Life at Operating Temperature	7.07	3.75
Cycles at 20°C	#N/A	848
Cycles vs Temperature Factor	0.713774172	0.713774172
Cycles at Operating Temperature	#N/A	605.12
Cycles / day	1	1
Cycle Life at Operating Temperature	#N/A	1.7
Service life (years)	#N/A	1.7

Application (Bold = Default Value)	
Ups	Telecom
DataSafe XE	PowerSafe SBS EON
DataSafe HX	PowerSafe V-FT
DataSafe HX+	Standard AGM
PowerSafe SBS EON	PowerSafe SBS XL
PowerSafe V-FT	
Standard AGM	

Colour Index Chart 1 & 4		
DataSafe XE	0	0
DataSafe HX	167	167
DataSafe HX+	117	120
PowerSafe SBS EON	255	0
PowerSafe V-FT	255	246
Standard AGM	82	82
PowerSafe SBS XL	184	0
PowerSafe SBS XL	184	0
PowerSafe SBS EON	255	0
PowerSafe V-FT	255	246

Annuity Calcs		
PowerSafe SBS XL	PowerSafe SBS EON	PowerSafe V-FT

N/a	N/a	N/a
N/A	N/A	N/A

$$A = I * \frac{(1+r)^n * r}{(1+r)^n - 1}$$

A = Payment amount per periodI = value of investment per batteryn = number of periods (years, months)

r = interest rate

S_L= Service life

Currency
€
\$
£

Technology	
TPPL	20
Std AGM	35
	20

Selected product range 1
PowerSafe SBS XL
TPPL
20

1.15	
1.15	
1.2	

PowerSafe V-FT
3.01
505
0.713774172
360.19
1
1.0
1.0

0	
167	
121	
0	
0	
82	
0	
0	
0	
0	

A A*S_L

Selected product range 2	Selected product range 3	Grid
PowerSafe SBS EON	PowerSafe V-FT	Stable/ reliable
TPPL	TPPL	Unstable/ unreliable
20	20	

Туре	
62	
92	
100	
155	
170	
190	

C10 wh	
124	
184	
201	
311	
342	
382	